



14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8- Power Cables

3rd stakeholder meeting

Paul Van Tichelen

Brussels, DG Enterprise 13 November 2014

Agenda

- » 10:00-10:10 Welcome
- » 10:10-10:20 Short presentation of participants
- » 10:20:-11:20 Tasks 1-3 in a nutshell, incl. latest enquiry input
- » 11:20-12:30 Task 4-6, based on updated input incl. improvement options and sensitivity analysis
- » 12:30-13:30 Break & lunch
- » 13:30-14:00 Draft Task 7 on policy options including discussion
- » 14:00-14:20 Draft Task 7 on need for updated and/or new standards, including discussion
- » 14:20-14:50 Draft Task 7 on 2025 scenarios
- » 14:50-15:20 Draft Task 7 on impact including discussion and stakeholders position input
- » 15:20-15:30 Any other business
- » 15:30-15:40 Planning stakeholder feedback and finalization





EC policy officer & VITO Study Team

- » EC policy officer: Cesar Santos
- » VITO Preparotory Study Team:
 - Arnoud Lust: Contract Manager: Arnoud Lust (FC ENTR/29/PP/FC Lot
 2) and FC DG ENER Lot 1
 - » Main author power cables study&coordinator: Paul Van Tichelen
 - » Co-authors:
 - » Dominic Ectors (market and use data, ..)
 - » Marcel Stevens (technical standards, ..)
 - » Wai Chung Lam (LCA, MEErP and scenarios, ..)
 - » Administrative contacts:
 - » Magalie Wellens +32 14 33 58 04
 - » Katrien Bultynck +32 14 33 59 96
 - » Website: Karel Styns (webmaster).



Introduction ErP Directive

- » Background is the Ecodesign Directive 2009/125/EC:
 - » Framework Directive
 - » binding requirements through 'Implementing Measures' (EC Regulation ..)
 - » For products but it is possible to introduce information requirements for components and sub-assemblies
 - Product groups are first identified in a Working Plan, such as power cables in the 2nd working plan year 2012-2014
 - » A preparatory study provides the necessary information to prepare for the next phases in the policy process, a.o.: impact assessment, the consultation forum, ..)
 - » Approach of preparatory study is well defined in the Methodology for the Ecodesign of Energy-related Products (MEErP)
 - » Further info: http://ec.europa.eu/enterprise/policies/sustainablebusiness/ecodesign/index_en.htm

vision on technology


MEErP in a nutshell

- » Tasks in MEErP (chapters in final report):
- » Task 1 Scope (definitions, standards and legislation, first screening);
- » Task 2 Markets (volumes and prices);
- » Task 3 Users (product demand side);
- » Task 4 Technologies (product supply side, includes both BAT and BNAT);

14/11/2014

© 2013, VITO NV

- » Task 5 Environment & Economics (Base case LCA & LCC);
- » Task 6 Design options;
- » Task 7 Scenarios (Policy, scenario, impact and sensitivit
- » Tasks 1 to 4 can be performed in parallel



MEErP structure



Planning

- » 28 Jun 2013 ■Project kick-off meeting with EC
- » July 2013 Launch website www.erp4cables.net
- » Aug 2013 Launch first series of enquiries to registered stakeholders
- » 5 dec 2013 1st stakeholder meeting on Draft Task 1-3
- » 3 June 2014 2nd stakeholder meeting on Draft Task 1-5
- » 13 Nov 2014
 3rd stakeholder meeting on Draft Task 1-7
- » End Feb 2015
 Publication Final Report Task 1-7







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 1

Paul Van Tichelen

Brussels, DG Enterprise 3rd of June2014

Task 1: Content

- » "Product scope" of the study
- » Product categories based on
 - » Prodcom
 - » EN- or ISO-standards
 - » Other product-specific categories
- » Definitions & Terminolgy
- » Primary & secondary product performance parameters
- » Product Standards & Legislation
 - » EU level
 - » Member state level
- » First screening



Task 1: Product scope

» SCOPE: 'losses in installed power cables in electric circuits in buildings after the meter' taking into account the electrical installation as a system.

Out of the scope:

- » Losses in circuit breakers;
- » Losses or inefficiency in the loads connected to the circuit;
- » Losses due to poor connections ;
- » Utility cables for transmission (HV) and distribution (MV,LV) of electrical energy;
- » Power cables for Nuclear power;
- » Power cables for hazardous locations (in ATEX zones);
- » Cables used for power plants such as PV, Wind,;
- » Outdoor cables: Cables used in process installations (e.g. chemical and petrochemical plants), railway cables,..;
- » Cables for mobile applications: (electric) cars, ships, metro, ...
- » Busbar Trunking systems;



Task 1: Product performance parameter

- » Primary product(cicuit) performance paramater or "Functional unit":
 - » Cable: "Current-Carrying capacity" of the cable/conductor [Amperes]
 - » Circuit: > In: is rated current for the circuit and is determined by the protective device (safety fuses or circuit breakers) of the circuit;
- » Secondary:
 - » CSA, LF, Kf, cos θ, L, ..



Task 1: Measurement & test standards

- » Conductors & cables
 - » EN13601 & -13602: Copper and copper alloys
 - » EN 60228: Conductors of insulated cables
 - » Class1,2,5,6; Links 'Nominal CSA with Rdc max', ...
 - » EN 50525-1: Low voltage energy cables
 - » EN 50395: Electrical test methods for low voltage energy cables



Task 1: Measurement & test standards

- » Electrical installation:
 - » (IEC)HD 60364-5-52: LV electrical installations ... wiring systems
 - » Correction factors, methods of installation, dV max,
 - » IEC 60287-1-1: Calculation of current rating & losses -100% load factor
 - » IEC 60287-3-2: Calculation of current rating Economic optimization single cable segment – not for distributed loads
 - » IEC 60364-6: Low Voltage electrical installations verification
 - » IEC 60364-8-1 / FprHD 60364-8-1: 2013: Low voltage electrical installation - Part 8-1: Energy efficiency – DRAFT version:
 - » Reduction of energy losses in wiring:
 - » Reducing the voltage drop. Reference to IEC 60364-5-52;
 - » Increasing the cross sectional area. Reference to IEC 60287-3-2;
 - » Power factor correction to improve the power factor of the load circuit;
 - » Reduction of harmonic currents at the load level.

» Qualitative but not quantitative?



Task 1: First screening

- » Note: these values are updated in later chapters!
- » Focus in taks 3-6 on service and industry sector







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 2

Paul Van Tichelen

Brussels, DG Enterprise 3rd of June 2014

Content

- » 2.1 Generic economic data
- » 2.2 Market and stock data
 - » 2.2.1 Sales data
 - » 2.2.2 Stock data
- » 2.3 Market trends
- » 2.4 Consumer expenditure base data
- » 2.5 Recommendations



Market and stock data: summary

Sector	Product life	Service life	Vacancy	Stock growth rate	Demolition rate	Replace- ment sales rate	New sales rate	Total sales rate	Stock (Reference year: 2010)	
Unit	Year	Year	%	% p.a.	% p.a.	% p.a.	% p.a.	% p.a.	kTon Cu	%
Residential sector	64.00	60.80	5%	0.90%	0.10%	1.18%	0.90%	2.08%	5241	43%
Services sector	25.00	23.75	5%	1.90%	0.20%	3.20%	1.90%	5.10%	3250	26%
Industry sector	25.00	23.75	5%	2.90%	0.20%	2.80%	2.90%	5.70%	3825	31%
Total sector (weighted)	41.60	39.52	5%	1.79%	0.16%	2.22%	1.79%	4.00%	12316	100%



Product/circuit cost

- » Cost of circuit:
 - » Cable cost (CSA [mm²] x I [m] x N) an average discounted cable price of 0.09434 €/ (mm². m).

© 2013, VITO NV

- » Connector cost
- » Installation times per cable type
- » Average hourly rate (23,7 euro/h)

						Discounted
		Minimum	Maximum		Connector	connector
			wire size	CSA	price	price
-		wire size				
tvn	90	mm ²	mm ²	mm ²	€	€
~ y P		0.14		1	0.87	0.54
typ uro	/1- \	0.14	4 4	1.5	0.87	0.54
uro	/n)	0.14	4 4	2.5	0.87	0.54
		0.14	4 4	4	0.87	0.54
		0.2	2 10	6	1.61	0.97
u based cable	s	0.2	2 10	10	1.61	0.97
		0.5	5 16	16	2.11	1.25
Installation	Installation	1.5	5 25	25	2.11	1.07
time per meter	time for the cable ends	1.5	5 50	35	4.85	2.84
Min 1.75	Min 5	1.5	5 50	50	4.85	2.84
2.45	7	16	5 70	70	11.79	7.31
3.15	9	25		95	22.11	13.71
3.85 5.25	12 12					
5.95	12	35	5 150	120	28.96	17.96
7	17	35	5 150	150	28.96	17.96
8.75	20.4	70	240	185	35.36	21.92
9.8 10.5	25.5 30.6	70	-	240	35.36	21.92
11.9	30.6	/	240			
12.6	45			300	44.20	27.40
14	45			400	58.93	36.53
15.75	60		1			
17.5	60			500	73.67	45.67
21	85			630	92.82	57.54
24.5	120			1		
28 35	200					
42	480					



17

Discounted

Copper long-term availability

- » Many comments received:
- >> Update needed, tekst added in 2.4.1 on 'purchase price' should fit in 2.4.1.1 'copper long term availability' (both will be integrated).
- » Main change: copper is not considered as critical raw material, references added to other EU studies that focus in this topic, e.g.:
 - » http://ec.europa.eu/enterprise/policies/rawmaterials/critical/index_en.htm







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 3

Paul Van Tichelen

Brussels, DG Enterprise 3rd of June 2014

Task 3 Users

» Systems aspects of the use phase for ErPs with direct impact

- » Definition of the User and context
- » Loss parameters directly related to the cable itself
- » Other functional cable parameters not directly related to losses
- » Loss parameters directly related to the electrical circuit and network topology
- » Parameters related to the building and loading
- » Formulas used for power losses in cables
- » End of Life behaviour
- » Local infrastructure (barriers & opportunities), e.g. cable bending
- » Recommendations



CSA, parameter

Table-3-2:-Minimum-and-maximum-cable-cross-sectional-areas-per-circuit-type¶

•Sector¤	Circuit-application-type¤	CSA∙ (mm²)∙ min¤	CSA¶ (mm²)¶ max¤	×
	Distribution · circuit×	6¤	16¤	¤
 Residential¤ 	Lighting. circuit×	1×	2.5×	×
- Residentiala	Socket-outlet circuit×	1.5×	6 ⁸ ×	×
	Dedicated circuit×	2.5×	6×	¤
	Distribution circuit×	10¤	600¤	×
•Services¤	Lighting. circuit×	1.5×	2.5×	×
-ServicesA	Socket-outlet circuit×	1.5×	6×	×
	Dedicated circuit×	2.5×	95×	¤
	Distribution circuit×	25×	600¤	×
To do atomica	Lighting circuit×	1.5×	2.5×	×
 Industry¤ 	Socket-outlet circuit×	1.5×	10 ⁸ ¤	×
	Dedicated circuit×	2.5×	600¤	×



Circuit length, parameter (from questionnaire)

LO]|

.

۱9

Table+3-4:+Average+circuit+length+in+meters+according+questionnaire5+¶

Sector	Circuit application type	Average length min (m)	Average length ref (m)	Average length max (m)
	Distribution circuit	15	21	54
Residential	Lighting circuit	10	20	60
Residential	Socket-outlet circuit	5	24	100
	Dedicated circuit	5	18	80
	Distribution circuit	20	56	200
Services	Lighting circuit	12	44	240
Services	Socket-outlet circuit	10	53	300
	Dedicated circuit	10	51	300
	Distribution circuit	30	83	240
Industry	Lighting circuit	20	68	340
	Socket-outlet circuit	15	72	500
	Dedicated circuit	15	79	400
Co	orrectionFactor	1	1	2

20 21 22

1

9



Load factors (α_c) and load form factors (Kf)

		Lię	ghting circ	uit	Socke	et-outlet o	ircuit	Dedicated circuit		cuit	Distribution circuit		
		Low	Ref	High	Low	Ref	High	Low	Ref	High	Low	Ref	High
Desidential	Kf	3.12	2.11	1.67	4.38	1.74	1.34	4.61	3.99	3.12	1.24	1.14	1.08
Residential sector	ας	0.01	0.05	0.10	0.00	0.04	0.10	0.01	0.02	0.05	0.01	0.06	0.22
	Kf.αc	0.03	0.11	0.17	0.01	0.06	0.13	0.02	0.08	0.14	0.02	0.07	0.23
Comisso	Kf	1.50	1.27	1.16	1.50	1.27	1.16	1.37	1.21	1.13	1.37	1.21	1.13
Services sector	ας	0.07	0.24	0.41	0.04	0.15	0.24	0.14	0.41	0.54	0.14	0.41	0.54
	Kf.αc	0.11	0.31	0.48	0.06	0.19	0.27	0.20	0.49	0.61	0.20	0.49	0.61
la du atau .	Kf	1.11	1.06	1.03	1.11	1.06	1.03	1.03	1.01	1.00	1.05	1.02	1.01
Industry sector	ας	0.12	0.34	0.54	0.06	0.27	0.46	0.23	0.61	0.76	0.22	0.57	0.72
	Kf.αc	0.13	0.36	0.55	0.06	0.29	0.47	0.24	0.61	0.76	0.23	0.58	0.72
ac correction	n factor	0.5	1	1	0.5	1	1	0.5	1	1	0.5	1	1



End of life parameters

- » More info added on recycling
- » source: kept similar with the MEErP default values also used in other ErP Ecodesigns studies

	Bulk Plastics	TecPlastics	Ferro	Non-ferro	Coating	Electronics	Misc. , excluding refrigant & Hg	refrigerant	Hg (mercury), in mg/unit	Extra	Auxiliaries
EoL mass fraction to re-use, in %	1%	1%	1%	0%	1%	1%	1%	1%	1%	1%	5%
EoL mass fraction to (materials) recycling, in %	29%	29%	94%	95%	94%	50%	64%	30%	39%	60%	30%
EoL mass fraction to (heat) recovery, in %	15%	15%		0%		0%	1%	0%	0%	0%	10%
EoL mass fraction to non-recov. incineration, in %	22%	22%	0%		30%	5%	5%	5%	10%	1 0 %	
EoL mass fraction to landfill/missing/fugitive, in %	33%	33%	5%		19%	29%	64%	55%	29%	45%	



Product life times

	short pro	oduct life	Refe	erence	long product life		
	Replace-		Replace-		Replace-		
Sector	ment rate	Product life	ment rate	Product life	ment rate	Product life	
Unit	%	year	%	year	%	year	
Residential sector	2.10%	40	1.18%	64	0.80%	84	
Services sector	7.08%	13	3.20%	25	1.70%	40	
Industry sector	7.08%	12	2.80%	25	1.37%	40	



Formula 3.5 used for power losses in cables

Ecircuit,(y) [kVAh] = Kd . Rt . Imax² . (α c . Kf)² . 8760 / 1000 (formula 3.5)

where,

- » Kd = the distribution factor
- » R_t = cable resistance at temperature t (see formula 3.2)
- » Imax = the maximum rated current of the cable
- » α_c = The corrected load factor (circuit level-distributed)
- » Kf = Load form factor (=Prms/Pavg)
- » PF = the power factor of the load served by the power cable







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 4

Dominic Ectors

Brussels, DG Enterprise

13 November 2014

Task 4: Technologies

» BAT

- » Product level (power cable)
- » System level (electrical installation/-circuit)
- » BNAT
 - » Product level (power cable)
 - » System level (electrical installation/-circuit)
- » Production, distrubition and End of Live (Task 3)
- » Improvement options & recommendations



Task 4: Technologies - BNAT

- » BNAT at Product level (power cable)
 - »?
- » BNAT at System level (electrical installation/-circuit)
 - » Energy efficiency at appliance level
 - » Building and home automation
 - » Peak reduction control systems
 - » DC power distribution in commercial buildings



Task 4: Technologies - BNAT

- » DC power distribution in commercial buildings, as for instance promoted by the EMerge Alliance.
- » This system will use 380 VDC/24VDC instead of 110 or 230 VAC
- The rationale is that cable insulation is related to the peak voltage(Vpeak). In AC systems peak voltage is Vrms.V2 = 325 Vpeak. In DC systems the peak voltage is equivalent to the VDC. As a consequence an identical cable with identical insulation would need **less current in DC** (e;g.: 325VDC, 1A, 325 VA) compared to AC (e.g. 230 Vrms, 1.41A, 325 W) and will therefore reduce the cable losses.
- Such a switch from AC to DC is complex as it requires another concept of power distribution with different converters, protection switches, distribution transformers, etc. Therefore it will not be considered as a viable BAT improvement option.



Task 4: Production, distribution and End of Live

- » Section on Power Cable Manufacturing added
- » Bill of Material Cu adapted
 - » Using 5(4) cores (or 4 x 1 core)
 - » Pricing based upon EURO/mm².m
- » Bill of Material added for Al cable
- » Cable composition added (from stakeholder)

Cable Part	Composition	% in weight
PVC sheath	PVC resin	45
	Ca Carbonate filler	25
	Plasticizer (DIDP)	25
	Lubricant, stabilizer and others	5
XLPE insulation	LDPE	97
	Crosslinking compound (Silane based)	3



.....

Task 4: Distribution

» Not changed



Task 4: Improvement options & Recommendations

Option Name	Description						
At cable level							
Low loss cable as a product	No BNAT technologies are available at cable level that could reduce the energy losses in an economical feasible manner. Labelling information on the cable about energy losses is not an improvement option and can be implemented by the scenarios mentioned in "at circuit level" part.						
At circuit le	vel (system level)						
Stx	Using, for a particular circuit and load, a cable with a larger CSA ($S+x$) than necessary (according current standards and regulation) will result in a lower cable resistance R, and thus lower energy losses. The CSA increments are conform the current, standardized CSA values (no new CSA values are considered).						
25	By installing, for a particular circuit and load, instead of one cable with a particular CSA_x one or more cables in parallel with the same CSA (or even smaller CSA than the original foreseen CSA_x) the losses in the circuit can be reduced.						
Topology	Keeping the topology in mind when designing the electrical system of a building can reduce the energy losses in the circuits. For instance, to keep losses to a minimum, the main distribution transformers and switchboards are to be located to keep the distances (circuit lengths) to main loads to a minimum. The building's use, construction and space availability has to be taken into account to obtain the best position. One such method to determine the best position is the barycentre method ⁹ .						







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 5

Dominic Ectors

Brussels, DG Enterprise

13 November 2014

Task 5: aim

» Task 5: Environment Economics

- » Base Case Environmental Impact Assessment(EcoReport Tool)
- » Base Case Life Cycle Costs for consumer
- » Base Case Life Cycle Costs for society
- » EU wide impact
- » to assess environmental and economic impacts of the different base cases.
- based upon EcoReport Tool version 3.06, as provided with the MEErP 2011 methodology.



Task 5 content (1)

- » 5.1 Product-specific inputs
 - » 5.1.1 Identification of base cases
 - » 5.1.2 Manufacturing of the product: Bill Of Materials
 - » 5.1.3 Distribution phase: volume of packaged product
 - » 5.1.4 Use phase
 - » 5.1.5 End of Life (EoL)
 - » 5.1.6 Life Cycle Cost Inputs
- » 5.2 Base case environmental impact assessment (using EcoReport)
- » 5.3 Base case Life Cycle Cost for consumer
- » 5.4 Base case Life Cycle Costs for society



Task 5 content (2)

- » 5.5 EU totals
 - » 5.5.1 Stock specific inputs
 - » 5.5.2 Environmental impact at EU-28
 - » 5.5.3 Economic assessment at EU-28
- » 5.6 Cross checks



5.1 Product-specific inputs 5.1.1 Identification of base cases

- » Services sector
 - » Base case 1: typical distribution circuit
 - » Base case 2: typical lighting circuit
 - » Base case 3: typical socket-outlet
 - » Base case 4: typical dedicated circuit
- » Industry sector
 - » Base case 5: typical distribution circuit
 - » Base case 6: typical lighting circuit
 - » Base case 7: typical socket-outlet
 - » Base case 8: typical dedicated circuit
- » Industry sector
 - » Base case 9: The same base case as base case 8, but instead of copper the cable conductors are of aluminium.



5.1.2 Bill Of Materials: base cases

- » Conductor material: Cu or Al
- Insulation material: 100% LDPE (3% silane based crosslinking compound in the XLPE insulation, however due to the limited list of materials in the EcoReport tool 100% LDPE is used for the calculations)
- » Sheath material, composed of:
 - » 50% of the sheath material weight: PVC (not recycled);
 - » 25% of the sheath material weight: talcum filler as filler material in the sheath (talcum filler in EcoReport tool instead of calcium carbonate)
 - » 25% of the sheath material weight: bitumen (As it is the closest to a plasticizer in the EcoReport tool);
- » Filler material: 100% talcum filler.



5.1.2 Bill Of Materials: base cases

Table 5-3: Material resource input for base case 1

Pos	MATERIALS Extraction & Production	Weight	Category	Material or Process
nr	Description of component	ing	Click & select	select Categoryfirst !
1	Conductor		4- Non- ferro	30 - Cuwire
2	Insulation		1- Blk Plastics	1-LDPE
3	Sheath - PVC	26931.7	1- Blk Plastics	8-PVC
4	Sheath - Filler	13465.8	2-TecPlastics	18 - Talcumfiller
5	Sheath - plasticizer	13465.8	7-Misc.	56-Bitumen
6	Filler material		2-TecPlastics	18 - Talcumfiler



5.1.3 Distribution phase: volume of packaged product

» Not changed, except there are 9 bases cases



5.1.4 Use phase

Parameter	Unit	т				Base cases					
Base case id		Γ	BC1	BC2	BC3	BC4	BC5	BC 6	BC7	BC8	BC9
		Γ	Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
Sector			sector	sector	sector	sector	sector	sector	sector	sector	sector
					Sock et-				Socket-		
			Distributio	Lighting	outlet	Dedicated	Distributio	Lighting	outlet	Dedicated	Dedicated
Application circuit			n árcuit	circuit	circuit	circuit	n circuit	circuit	dircuit	<u>árcuit</u>	circuit
Loaded cores		I.	6	2	2	3	12	2	2	3	3
Cables in parallel		I.	2	1	1	1	4	1	1	1	1
Conductor material		I	Cu	Cu	Cu	Cu	Cu Cu	Cu	Cu	Cu	AI
In per cable	Α	I	289	10	16	62	451	10	16	156	156
CSA	mm²	I	120	1.5	2.5	10	300	1.5	2.5	35	70
Length of drauit	m	I	56	44	53	51	83	68	72	79	79
	Ω.m										
ρŧ	m²/m	-	0.0167	0.0167	0.0167	0.0167	0.0167	0.0167	0.0167	0.0167	0.0265
R (formula 3.2) per wire	Ω	С	0.008	0.485	0.353	0.084	0.005	0.752	0.481	0.037	0.030
Kd		I.	1.00	0.37	0.40	1.00	1.00	0.37	0.44	1.00	1.00
Kf		I.	1.21	1.27	1.27	1.21	1.02	1.06	1.06	1.01	1.01
ας		I.	0.41	0.24	0.15	0.41	0.57	0.34	0.27	0.61	0.61
Pf		I	0.80	1.00	0.80	0.80	0.80	1.00	0.80	0.80	0.80
Annual energy loss (form ula 3.5) per loaded core	kWh	с	1392.06	15.22	10.81	694.00	2797.39	31.38	39.16	3011.51	2389.38
Annual energy loss (formula 3.5) per BC	kWh	с	8352.36	30.44	21.61	2082.01	33568.63	62.75	78.33	9034.54	7168.13
Annual energy transported (formula 3.6) per BC	kVAh	с	1,383,543	6,233	4,787	148,731	5,121,230	7,249	7,423	465,153	465,153
Energy loss ratio (form ula 3.7)		С	0.60%	0.49%	0.45%	1.40%	0.66%	0.87%	1.06%	1.94%	1.54%

$$\begin{split} & \mathsf{E}_{\mathsf{circuit},}(y) \ [\mathsf{kVAh}] = \mathsf{Kd} \ . \ \mathsf{R}_{\mathsf{t}} \ . \ \mathsf{I}_{\mathsf{circuit}}^2 \ . \ (\alpha \ . \ \mathsf{Kf})^2 \ . \ 8760 \ / \ 1000 \ \ (\mathsf{formula} \ 3.5) \\ & \mathsf{E}_{\mathsf{active}}(y) \ [\mathsf{kWh}] = \underline{\sqrt{3}} \ . \ \mathsf{V} \ . \ \mathsf{I}_{\mathsf{circuit}} \ . \ \alpha \ . \ \mathsf{Kf} \ . \ \mathsf{PF} \ . \ 8760 \ / \ 1000 \ \ (\mathsf{1-}, \underline{3-}\mathsf{phase}) \ \ (\mathsf{formula} \ 3.6) \end{split}$$

Loss ratio = $E_{circuit}(y) / E_{active}(y)$ (formula 3.7)



5.1.5 End of Life (EoL)

- » Not changed compared to previous version
 - » Defaults values of the EcoReport have been used for recycling rates of the materials
 - » Only the re-use of metals is set to 0% instead of 1% and recycling of metals is set to 95% instead of 94% (see section 3.3 in Task 3)
- » Remark Europacable: do not agree on 5% waste/landfill



5.1.6 Life Cycle Cost Inputs

	Unit					Bases cases	definiton				
Base case id			BC1	BC2	BC3/	To be ch	ecked	BC6	BC7	BC8	BC9
			Services	Services	Services		CERCU	Industry	Industry	Industry	Industry
Sector			sector	sector		sector	sector	sector	sector	sector	sector
					Socket-				Socket-		
			Distribution	Lighting	outlet	Dedicated	Distribution	Lighting	outlet	Dedicated	Dedicated
Application circuit			dirauit	a rait	circuit	circuit	circuit	dircuit	dircuit	circuit	circuit
LCC data	T					T			1	1	
Year			2010	2010	2010	2010	2010	2010	2010	2010	2010
Electricity rate	€/kWh		0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11
	_							_			
Product price for 1 meter cable	€	•	56.60	0.71	1.18	4.72	113.21	0.71	1.18	16.51	18.79
Price connectors	€		359.20	35.59	24.87	15.54	876.80	40.94	18.07	43.25	111.31
Bace dase product price	€	С	6727.15	66.41	87.11	254.01	38235.44	88.70	102.97	1339.24	1586.41
Base case installation cost	€		693.23	78.65	98,45	137.78	3572.78	107.30	113.40	334.55	391.53
Product life	Year		25.00 🔨	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
Product service life	Yèşr		23.75	2375	23.75	23.75	23.75	23.75	23.75	23.75	23.75
	·	\backslash					du at life	OF inct	and of 1	1.00000	
			\			Pro	duct life	25 INST	ead of 1	4 years	
Added co	nnec	cto	r cost, p	er node	;						
		_	\								
Cost	per r	ne	eter + er	nds (per	node)						
				\backslash							
				Dis	scounte	d produ	ct prices	sexcl \	/AT bas	ed	
									,		
🚄 vito				up		<u>O/mm².</u>	.[[]				
				//							
vision on technol	logy		//		4/11/2014					44	
		/	///	C	2013, VITO NV						

5.2 BASE CASE ENVIRONMENTAL IMPACT ASSESSMENT (USING ECOREPORT)



EcoReport tool: input summary

Is split up in different components in EcoReport tool

Table /5-8: EcoReport tool input parameters per base case

	Unit				Base cas	ses: ecorepo	rt input			
Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
CSA	mm ²	120	1.5	2.5	10	300	1.5	2.5	35	70
Conductor material	5	600075.0	2904.1	5864.9	22471.9	3520440.0	4500.6	8001.0	122126.4	74182.5
Insulation material	5	26821.0	935.3	1349.2	2223.0	147862.8	1449.5	1840.7	7.8	14.9
Sheath material	5	53863.3	3458.1	4673.7	6561.1	270615.7	5359.1	6376.0	16512.0	31330.4
Filler material	5	146340.7	1794.8	2652.4	7140.9	638181.6	2781.4	3618.4	30692.3	66196.7
Annual energy loss (formula 3.5) per BC	kWh	8352.36	30.44	21.61	2082.01	33568.63	62.75	78.33	9034.54	7168.13
Volume	m3	0.93	0.02	0.02	0.04	5.17	0.02	0.03	0.18	0.39
Product life	Year	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
Product service life	Year	23.75	23.75	23.75	23.75	23.75	23.75	23.75	23.75	23.75
Bace case product price	€	6727.15	66.41	87.11	254.01	38235.44	88.70	102.97	1339.24	1586.41
Annual sales (base case units.)	mln. Units	0.13	2.86	3.77	0.98	0.03	1.78	2.00	0.24	0.24
EU Stock (base case units)	mln. Units	3.23	71.43	94.32	24.62	0.71	44.44	49.99	5.94	5.94
Base case installation cost	ž	693.23	78.65	98.45	137.78	3572.78	107.30	113.40	334.55	391.53
Electricity rate	€/kWh	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11
EoL mass fraction to re-use, non- Ferromaterial	%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Conductor material		Cu	ş	Cu	Cu	Cu	Cu	Cu	Cu	AI

Added Including connector cost



5.3 BASE CASE LIFE CYCLE COST FOR CONSUMER



Base Case Life Cycle Cost for consumer

Table 5-18: Life Cycle Costs for consumer per base case

	Unit				Life Cycl	e Costs per b	ase case			
Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
Sector		Services sector	Services sector	Services sector	Services sector	Industry sector	Industry sector	Industry sector	Indust ry sector	Industry sector
Application circuit		Distributio n circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distributio n circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Dedicated circuit
Product price	€	6727.15	66.41	87.11	254.01	38235.44	88.70	102.97	1339.24	1586.41
Installation/acquisition costs (if any)	€	693.23	78.65	98.45	137.78	3572.78	107.30	113.40	334.55	391.53
Electricity	€	22,968.99	83.72	59.43	5725.54	92313.73	172.57	215.40	24845.00	19712.35
Tota	€	30389.36	22.8.78	244.99	6117.33	134121.95	368.57	431.77	26518.79	21690.29
Produkt prike	%	2.2%	29%	36%	4%	29%	24%	24%	5%	7%
Installation/ acquisition costs (if any)	%	2%	34%	40%	2%	3%	29%	26%	1%	2%
Electricity	%	76%	37%	24%	94%	69%	47%	50%	94%	91%
Total	%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Including connector cost

Cost per meter + ends (per node)

Running costs discounted to their Net Present Value

5.5 EU TOTALS



EU totals: stock specific input

Table 5-20: Stock input parameters per base case

	Unit					Bases cases de	efiniton				
Base case id			BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
			Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
Sector			sector	sector	sector	sector	sector	sector	sector	sector	sector
			Distribution	Lighting	Socket-outlet	Dedicated	Distribution	Lighting	Socket-outlet	Dedicated	Dedicated
Application circuit			circuit	circuit	circuit	circuit	circuit	circuit	circuit	circuit	circuit
Stock and sales data (fixed total stock)											
Year			2010	2010	2010	2010	2010	2010	2010	2010	2010
EU Stock per base case cable (Conductor weight)	kg	Т	1.94E+09	2.07E+08	5.53E+08	5.53E+08	2.50E+09	2.00E+08	4.00E+08	7.25E+08	4.40E+08
EU Stock (units of 1 cable)	m	С	3.63E+08	3.11E+09	4.98E+09	1.24E+09	2.34E+08	3.00E+09	3.60E+09	4.66E+08	4.66E+08
	min.										
EU Stock (base case units)	Units	с	1.75	38.82	51.26	13.38	0.39	24.15	27.17	3.23	3.23
	min.										
Annual sales (base case units)	Units	с	0.07	1.55	2.05	0.54	0.02	0.97	1.09	0.13	0.13
BC weightfactor of total stock		Т	14.00%	1.50%	4.00%	4.00%	50.00%	4.00%	8.00%	14.50%	

three reference parameters had to be corrected to fit EU-28 stock and EU-28 electricity consumption: see crosschecks



Environmental impact at EU-28 (annual)

Table 5-21: EU-28 total annual environmental impacts from the installed stock

	Unit					Enviro nmen tal					
Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9	Total (BC1-BC8
Sector		Services sector	Services sector	Services sector	Servicessector	Industry sector	Industry sector	Industry sector	Industry sector	Industry sector	
		Distribution		Socket-outlet		Distribution		So dket-ou tlet			
Application circuit		dircuit	Lighting circuit	circuit	Dedicated circuit	circuit	Lighting circuit	dircuit	Dedicated circuit	Dedicated circuit	
Materials											
Plastics	Mt	0.028	0.015	0.029	0.014	0.028	0.015	0.021	0.010	0.022	0.16
Ferrous metals	Mt	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.00
Non -ferro us metals	Mt	0.078	0.008	0.022	0.022	0.101	0.008	0.016	0.029	0.018	0.29
Other resources & waste											
Total Energy (GER)	PJ	71.80	7.41	9.94	119.13	67.59	8.64	12.64	124.82	100.65	421.96
of which, electricity	TWh	6.82	0.60	0.61	12.86	6.05	0.75	1.05	13.44	10.70	42.16
Water (process)*	min.m3	0.07	0.08	0.15	0.06	0.08	0.08	0.11	0.03	0.06	0.67
Waste, no n-haz./ landfill *	Mt	0.04	0.01	0.01	0.06	0.03	0.01	0.01	0.06	0.06	0.22
Waste, hazardo us/inciner ated *	kton	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
Emissions (Air)											
Greenhouse Gases in GWP100	mt CO2eq.	3.17	0.33	0.46	5.12	3.02	0.38	0.57	5.37	4.35	18.43
Acidi fying agents (AP)	kt SO2eq.	34.76	3.70	7.98	28.57	40.12	3.85	6.80	31.53	19.63	157.29
Volatile Org. Compounds (VOC)	kt	1.37	0.13	0.14	2.59	1.22	0.16	0.23	2.70	2.15	8.55
Persistent Org. Pollutants (POP)	g i-Teq.	0.44	0.04	0.10	0.35	0.50	0.05	0.08	0.39	0,51	1.95
Heavy Metals (HM)	ton Ni eq.	4.94	0.54	1.33	2.42	6.13	0.54	1.02	2.85	1.05	19.76
PAHs	ton Nieq.	0.58	0.07	0.15	0.40	0.69	0.07	0.12	0.45	/ 1.96	2.53
Particulate Matter (PM, dust)	kt	1.39	0.88	1.59	113	1.57	0.85	1.17	0.99	1.53	9.56
Emissions (Water)										7	
Heavy Metals (HM)	ton Hg/20	7.64	0.84	2.17	2.62	9.76	0.81	1.59	3.29	1.05	28.72
Eutrophication (EP)	kt PO4	0.03	0.00	0.01	0.03	0.03	0.01	0.01	0.03	0.02	0.14

42 TWh, including production, distribution, use and EoL phase.



Economic assessment at EU-28 (annual)

Table 5-22: Total annual expenditure in the EU-28 per base case

	Unit		sector sector<										
Base case id	0	BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9			
		Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry			
Sector	0	sector	sector	sector	sector	sector	sector	sector	sector	sector			
		Distribution	Lighting	Socket-outlet	Dedicated	Distribution	Lighting	Socket-outlet	Dedicated	Dedicated			
Application circuit	0	circuit	circuit	circuit	circuit	circuit	circuit	circuit	circuit	circuit			
Product price	min. €	847.05	143.33	285.81	243.13	1074.73	124.44	189.43	313.33	364.64	3221.25		
Installation/ acquisition costs (if any)	mln. €	85.28	177.12	314.98	127.14	96.57	156.67	205.04	76.12	88.51	1238.92		
Electricity	mln.€	741.11	59.81	56.06	1409.45	655.56	76.69	107.69	1474.92	1170.22	4581.27		
Total	mln. €	1673.44	380.25	656.85	1779.73	1826.85	357.80	502.15	1864.36	1623.37	9041.43		
Product price	%	26%	4%	9%	8%	33%	496	6%	10%	11%	100%		
Installation/acquisition costs (if any)	%	7%	14%	25%	10%	8%	13%	17%	6%	7%	100%		
Electricity	%	16%	1%	1%	31%	1496	296	2%	32%	26%	100%		
Total	%	19%	4%	7%	20%	20%	496	6%	21%	18%	100%		



5.6 CROSS CHECKS



Cross-checks: correction

- » the outcome for the losses were too high.
- The bases cases as such, although abstract cases, are not representative for the average total stock and losses in Europe.
- Therefore corrections factors. With the fitted parameters the total energy transported by the base cases equals the energy consumed at EU level, and the stock equals the stock figures in Task 3.
- » Three reference parameters are corrected:
 - » The reference circuit length (Task 3) is multiplied by 1.84;
 - » The reference load factor (Task 3) is multiplied by 0.5;
 - » The weight distribution towards the circuits (Task 2) is altered (see Table 5-20).



Cross-checks: correction

» Potentially a lot of circuits in the stock have a relative lower loading and/or longer circuit length and/or higher share of bases case with lower loading. This is also something taken into account in the sensitivity analysis (Task 6).



Cross checks: fixed stock (sales, lifetime)

Table 5-23: EU-28 totals check: first method

	Unit	т				Base	cases				Total over
Base case id			BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	allBC
Sector			Services	Services	Services	Services	Industry	Industry	Industry	Industry	
Application circuit			Distribution	Lighting	Socket-	Dedicated	Distribution	Lighting	Socket-	Dedicated	
Method 1: fixed stock	kg	Т									7.08E+09
Energy distribution factor	%	1	100%	20%	20%	60%	100%	10%	15%	75%	
	mln.										
EU Stock (base case units)	Units	1	1.75	38.82	51.26	13.38	0.39	24.15	27.17	3.23	
	min										
Number of buildings per sector (Task 2 Table 2-9)	Units	1	11.41	11.41	11.41	11.41	2.58	2.58	2.58	2.58	
Annual energy loss (formula 3.5) per BC	kWh	1	3842.09	14.00	9.94	957.73	15441.57	28.87	36.03	4155.89	
Annual energy transported (formula 3.6) per BC	kVAh	1	691,772	3,117	2,394	74,365	2,560,615	3,625	3,712	232,577	
Checks							•			•	
Annual energy loss Eu-28 (=BC loss * #BC units)	TWh	С	6.74	0.54	0.51	12.81	5.96	0.70	0.98	13.41	34.91
Annual energy transported Eu-28 (=BC annual											
energy transport * #BC units)	TWh	С	1,213	121	123	995	988	88	101	750	
Annual energy transported Eu-28 corrected with											
energy distribution factor	TWh	С	1,213	605	614	1,658	988	875	672	1,000	
Number of BC units (circuits) per building		С	0.2	3.4	4.5	1.2	0.1	9.4	10.5	1.3	



Cross checks: fixed EU-28 electricity consumption

Table 5-24: EU-28 totals check: second method

	Unit					Base	cases				Total over
Base case id			BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	allBC
Sector			Services	Services	Services	Services	Industry	Industry	Industry	Industry	
Application circuit			Distribution	Lighting	Socket-	Dedicated	Distribution	Lighting	Socket-	Dedicated	
Method 2: fixed EU-28 energy consumption	TWh	$^{-1}$		90	04			10	30		1934
Energy distribution factor	%	1	100%	20%	20%	60%	100%	10%	15%	75%	
	mln										
Number of buildings per sector (Task 2 Table 2-9)	Units	1	11.41	11.41	11.41	11.41	2.58	2.58	2.58	2.58	
Annual energy transported (formula 3.6) per BC	kVAh	1	691,772	3,117	2,394	74,365	2,560,615	3,625	3,712	232,577	
EU28 energy consumption (distributed via energy											
distribution factor)	TWh	С	904.12	180.82	180.82	542.47	1029.62	102.96	154.44	772.21	1933.74
Checks											
Annual energy loss Eu-28 (=BC loss * #BC units)	TWh	С	5.02	0.81	0.75	6.99	6.21	0.82	1.50	13.80	35.90
BC stock (= EU-28 energy consumption / energy	mln										
transported per BC)	Units	С	1.31	58.02	75.54	7.29	0.40	28.41	41.61	3.32	215.90
BC stock (weight)	kTon	С	1443.07	310.02	815.24	301.62	2604.63	235.22	612.56	746.10	7068.48







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 6 - design options

Dominic Ectors

Brussels, DG Enterprise

13 November 2014

6.1 Identification of design options and assessment of their impacts

Table 6-1: Design options

			Unit	Т				Base	e cases defin	iton			
		Base case id			BC1	BC2	BC3	BC4	BCS	BC6	BC7	BCB	BC9
		Sector			Services sector	Services sector	Services sector	Services sector	Industry sector	Industry sector	Industry sector	Industry sector	Industry sector
		Application circuit			Distributio n circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distributio n circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Dedicated circuit
Design													
option	Description	Parameter											
	Business As												
BAU	Usual	CSA	mm²	Т	120	1.5	2.5	10	300	1.5	2.5	35	70
D1	S+1	CSA	mm²	I.	150	2.5	4	16	400	2.5	4	50	95
D2	S+2	CSA	mm²	Т	185	4	6	25	500	4	6	70	120
D3	S+3	CSA	mm²	I	240	6	10	35	630	6	10	95	150
		Cables in parallel											
D4	25	multiplicator		I.	2	2	2	2	2	2	2	2	2



6.2 Improvement of Ecoreport Impact indicators

» 6.2.1 Impact per parameter

		Unit				of which, e	lectricity (in p	rimary MJ)			
	Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
			Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
	Sector		sector	sector	sector	sector	sector	sector	sector	sector	sector
	Application circuit		Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Dedicated circuit
BAU	of which, electricity (in primary MJ)	м	1791182	6668	4845	445443	7202865	13662	17050	1932280	1534557
D1	of which, electricity (in primary MJ)	MJ	1435369	4091	3161	278676	5412938	8336	10838	1352990	1131613
D2	of which, electricity (in primary MJ)	MJ	1167395	2667	2255	178767	4323256	5381	7426	967408	897418
D3	of which, electricity (in primary MJ)	м	904406	1899	1586	128076	3438519	3775	4774	714232	718966
D4	of which, electricity (in primary MJ)	м	904390	3575	2761	223341	3642788	7204	8987	967858	770833
D1		%	-20%	-39%	-35%	-37%	-25%	-39%	-36%	-30%	-26%
D2	Versus BAU	%	-35%	-60%	-53%	-60%	-40%	-61%	-56%	-50%	-42%
D3	VEISUS DAU	%	-50%	-72%	-67%	-71%	-52%	-72%	-72%	-63%	-53%
D4		%	-50%	-46%	-43%	-50%	-49%	-47%	-47%	-50%	-50%

Table 6-3: Electricity



Impact (GWP)

		Unit				Greenho	ouse Gases in (GWP100			
	Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
			Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
	Sector		sector	sector	sector	sector	sector	sector	sector	sector	sector
	Application circuit		Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Dedicated circuit
BAU	Greenhouse Gases in GWP100	kg CO2 eq.		318	257	19145	323619	630	793	83067	66202
D1	Greenhouse Gases in GWP100	kg CO2 eq.		217	203	12088	252258	417	552	58554	49201
D2	Greenhouse Gases in GWP100	kg CO2 eq.	54234	171	187	7921	209279	314	438	42424	39463
D3	Greenhouse Gases in GWP100	kg CO2 eq.	44283	157	203	5859	177825	275	385	32031	32088
D4	Greenhouse Gases in GWP100	kg CO2 eq.	44292	210	209	9785	187796	392	505	42475	34289
D1		%	-18%	-32%	-21%	-37%	-22%	-34%	-30%	-30%	-26%
D2	Versus BAU	%	-32%	-46%	-27%	-59%	-35%	-50%	-45%	-49%	-40%
D3		%	-44%	-50%	-21%	-69%	-45%	-56%	-51%	-61%	-52%
D4		%	-44%	-34%	-18%	-49%	-42%	-38%	-36%	-49%	-48%

Table 6-7: Greenhouse Gases in GWP100



Impact (Heavy metals)

Table 6-11: Heavy Metals to air

		Unit					Heavy Metals				
	Base case id		BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9
			Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
	Sector		sector	sector	sector	sector	sector	sector	sector	sector	sector
	Application circuit		Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Dedicated circuit
BAU	Heavy Metals	mg Nieq.	39033	178	264	5299	195517	307	464	23809	15736
D1	Heavy Metals	mg Nieq.	40661	220	371	4082	218338	358	570	19779	11734
D2	Heavy Metals	mg Nieq.	44042	307	525	3776	248225	486	758	18313	9440
D3	Heavy Metals	mg Nieq.	50959	435	845	4046	292396	679	1178	18789	7721
D4	Heavy Metals	mg Nieq.	50984	253	453	3842	282202	406	669	18324	8229
D1		%	4%	23%	40%	-23%	12%	17%	23%	-17%	-25%
D2	Versus BAU	%	13%	72%	99%	-29%	27%	58%	63%	-23%	-40%
D3	VEISUS DAU	%	31%	144%	220%	-24%	50%	121%	154%	-21%	-51%
D4		%	31%	42%	71%	-27%	44%	32%	44%	-23%	-48%

Circuits with a low load factor have relatively a high increase of heavy metals



Impact (GWP) per life cycle phase, relative




Figure 6-1 Greenhouse Gases (in detail, each phase relative to total) in GWP100






Figure 6-2 Greenhouse Gases in absolute values (in detail, each phase relative to total) in GWP100

vision on technology

Greenhouse gas: Environmental payback period

Table 6-19: Greenhouse Gases: environmental payback period in years

	Unlt				Greenhous	e Gases : payb	ack period			
Base case ld		BC1	BCZ	BC3	BC4	BC5	BC6	BC7	BC8	BC9
		Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
Sector		sector	sector	sector	sector	sector	sector	sector	sector	sector
Application circuit		Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distribution circuit	Lighting	Socket- outlet circult	Dedicated	Dedicated circuit
Product lifetime	ye a rs	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
D1	ye a rs	1.80	3.45	9.61	0.35	2.59	2.59	3.61	0.34	0.45
DZ	ye a rs	2.30	5.58	14.07	0.56	2.76	4.20	5.28	0.52	0.66
D3	ye a rs	2.94	8.24	23.07	0.76	3.67	6.19	8.64	0.73	0.79
D4	years	2.95	7.00	16.71	0.51	4.17	5.26	6.27	0.55	0.83



6.2.3 Conclusion on EcoReport tool impact parameters

Table 6-20: best performing design option per parameter and base case

	Best performing design option per parameter and base case											
Base case id	BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8	BC9			
	Services	Services	Services	Services	Industry	industry	Industry	Industry	Industry			
Sector	sector	sector	sector	sector	sector	sector	sector	sector	sector			
			Socket-				Socket-					
	Dist ribution	Lighting	outlet		Distribution	Lighting	outlet	Dedicated	Dedicated			
Application circuit	circuit	circuit	ci rcuit	ci rcuit	circuit	circuit	circuit	ci rcuit	ci rcuit			
Other resources and waiste												
Total Energy (GER)	D3	D3	D2	D3	D3	D3	D3	D3	D3			
of which, electricity (in												
primary MI)	D4	D3	D3	D3	D3	D3	D3	D3	D3			
Water (process)	8 AU	8 AU	BAU	BAU	BAU	8 AU	BAU	BAU	BAU			
Waste, non-haz./landfill	D3	D3	D2	D3	D3	D3	D3	D3	D3			
Emissions (air)												
Waste, hazardous/												
incinerated	D3	D3	D3	D3	D3	D3	D3	D3	D3			
Greenhouse Gases in												
GWP100	D3	D3	D2	D3	D3	D3	D3	D3	D3			
Acidification, emissions	D2	D1	BAU	D3	D1	D1	D1	D3	D3			
Volatile Organic Compounds												
(VOC)	D3	D3	D3	D3	D3	D3	D3	D3	D3			
Persistent Organic Pollutants												
(POP)	D2	D1	BAU	D3	D1	D1	D1	D3	D3			
Heavy Metals	8 AU	8 AU	BAU	D2	BAU	8 AU	BAU	D2	D3			
PAHs	D1	8 AU	BAU	D3	D1	D1	BAU	D3	BAU			
Particulate Matter (PM, dust)	8 AU	B AU	BAU	D3	BAU	8 AU	BAU	D3	D1			
			Emis	ssions (water)							
Heavy Metals	8 AU	8 AU	BAU	BAU	BAU	8 AU	BAU	BAU	D3			
Eutrophication	D3	D1	BAU	D3	D2	D1	D1	D3	D3			



6.3 Impact on Life Cycle Cost

		Unit	Jnit Life Cycle Costs per base case per year										
	Base case id		BCL BCZ BCS BC4 BC5 BC6 Very low Simple										
			Services	Services	Services	Services	Industry	Indust					
	Sector		sector	sector	sector	sector	sector	secto	Payba	ick Pe	eriod ((SPP)	
			B (1)				B (1)		\ ~,~~			(0)	
	Application circuit		Distribution circuit	Lighting circuit	Socket- outlet circuit	Dedicated circuit	Distribution circuit	Lighting circuit	outlet circuit	circuit	Dedicated circuit		
		e							+				
	Product price Instellation cost	e	6727.15 695.23	66.41 78.65	87.11 98.45	254.01 137.78	38235.44 3572.78	88.70 107.30	102.97	1339.24 334.55	1586.41 391.53		
BAU		e	22968.99	83.72	59.43	5725.54	92313.73	172.57	215.40	24845.00	19712.35		
	Electricity cost	e	30889.36	228.78	244.99	6117.33	134121.95	368.57	431.77	26518.79	21690.29		
	Total	e	8319.14	86.96	124.45	401.55	50980.59	120.54	153.92	1894.67	221090.29		
	Product price	e	794.69	101.12	124.45	161.27	4281.80	120.34	135.92	362.39	422.59		
	Installation cost	e											
D1	Electricity cost Total	e e	18375.19 27489.02	50.23 238.31	37.15	3578.46 4141.29	69235.30 124497.69	108.54 362.04	134.62 429.79	17391.50	14524.89 17158.17		
		-				+44%		+32%	+36%	+35%	+33%		
	Purchase price compared to BAU		+23%	+30%	+34%		+32%			-26%			
	Total cost compared to BAU		-10%	+4%	+17%	-32%	-7%	-2%	-0%	-20%	-21%		
	SPP	years €	9.22	32.11 117.77	70.52	1.99 613.30	14.57 63725.73	22.63 168.30	24.39 236.31	2703.30	3.16 2802.23		
	Product price	e		128.81	153.16	200.52	6225.20	174.61	181.07	412.30	453.83		
	Installation cost	e	872.45			200.52			-		400.00		
D2	Electricity cost	e e	14898.80 26026.91	31.40 277.98	24.76	3104.03	55388.24 125339.17	64.71 407.62	89.75 507.12	12422.50 15538.10	1498.87		
02	Total	•											
	Purchase price compared to BAU		+50%	+70%	+87%	+108%	+67%	+75%	+93%	+86%	+65%		
	Total cost compared to BAU SPP		-14% 11.49	+2.2%	+52%	-49%	-7% 19.05	+11%	+17%	-41% 2.90	-32% 3.92		
		years €	13174.30	46.50	293.73	880.09	80294.42	264.75	372.16	3726.47	3434.42		
	Product price	-		157.89	178.68	227.98		204.75	208.92	444.83	5454.42		
	Installation cost	e e	1067.49	-7			7773.60						
D3	Electricity cost Total	e e	11484.49 25726.28	20.95	14.86 487.27	1635.87 2743.89	43958.92 132026.94	43.14 519.84	53.85 634.92	9153.42 13324.72	9199.10 13165.95		
05		•	/										
	Purchase price compared to BAU		+92%	+135%	+155%	+183%	+111%	+143%	+169%	+149%	+101%		
	Total cost compared to BAU SPP		-12%							-50%			
		years €	13454.30	77.72 132.82	160.89 174.21	4.38	23.92 76470.88	54.22 177.39	205.95	3.98 2678.48	4.73 3172.83		
	Product price	•											
	Instellation cost Electricity cost	•	1386.45 11484.49	157.30 41.86	196.91 29.72	275.56	7145.55 46156.87	214.60 86.28	226.81	669.10 12422.50	783.05 9856.17		
D4			26325.24	331.98	400.84	3646.34	129773.30	478.28	540.45	12422.50	13812.06		
04	Total	1	20025.24	10.0%	400.84	5040.54 ±10.0%							
	Purchase price compared to BAU					AURIS	+100%	+100%	+100%	+100%	+100%		
	Total cost compared to BAU SPP	Ver	y high	Sim	ple		-3% 22.64	+30%	+25%	-41%	-36% 5.02		
						רחמ	22.04	30.79	50.23	3.37	5.02		
	U	Pay	Dack	Peric	od (SF	(P)							
visio	on on technology			14/11	72014							67	
	/			~ ~ ~ ~ ~ ~									

6.4 Analysis of BAT and LLCC

Table 6-22: LLCC and BAT per base case

		Unlt					Base cases				
	Base case Id		BC1	BCZ	BC3	BC4	BC5	BC6	BC7	BC8	BC9
			Services	Services	Services	Services	Industry	Industry	Industry	Industry	Industry
	Sector		sector	sector	sector	sector	sector	sector	sector	sector	sector
					Socket-				Socket-		
			Distributio	Lighting	outlet	Dedicated	Distributio	Lighting	outlet	Dedicated	Dedicate d
	Application circuit		n clrault	drcult	clrault	circuit	n circuit	clrault	circuit	circuit	circuit
BAU	Total Energy (GER)	М	1844983	7289	5803	447921	7509255	14563	18316	1943151	1547287
D1	Total Energy (GER)	М	1502325	4900	4464	282332	5815923	9530	12574	1367955	1148097
DZ	Total Energy (GER)	MJ	1250532	3760	3990	184289	4800 293	7015	9753	988460	918571
D3	Total Energy (GER)	М	1011499	3351	4168	135517	4036890	5964	8255	742897	744630
D4	Total Energy (GER)	MJ	1011881	4706	4566	2 28186	4255457	8896	11408	989490	796183
BAU	LCC	۹	30389.36	228.78	244.99	6117.33	134121.95	368.57	431.77	26518.79	21690.29
D1	LCC	€	27489.02	238.31	285.57	4141.29	124497.69	362.04	429.79	19648.56	17158.17
DZ	LCC	€	26026.91	277.98	372.07	3104.03	125339.17	407.62	507.12	15538.10	14764.93
D3	LCC	€	25726.28	361.19	487.27	2743.89	132026.94	519.84	634.92	13324.72	13165.95
D4	LCC	€	26325.24	331.98	400.84	3646.34	129773.30	478.28	540.45	15770.08	13812.06
	BAT		D3	D3	D2	D3	D3	D3	D3	DB	D3
LLCC			D3	BAU	BAU	D3	D1	D1	D1	DB	D3



6.5 Long term potential (BNAT) & systems analysis

» 380 VDC systems replacing 230 VAC



6.6 Sensitivity analysis

» 6.6.1 Sensitivity to circuit loading

- » the load factor;
- » load form factor;
- » Kd factor;
- » number of nodes per circuit.
- » 6.6.2 Sensitivity to length of the circuits
- » 6.6.3 Sensitivity to product lifetime




6.6.1 Sensitivity to circuit loading

Table 6-32: 0	design	option	sensitivity	to	circuit	use	(load)
---------------	--------	--------	-------------	----	---------	-----	--------

	BAT -	load sensi	itivity	LLCC - load sensitivity				
	low	ref	high	low	ref	high		
BC1	D3	D3	D3	BAU	D3	D3		
BC2	D1	D3	D3	BAU	BAU	D1		
BC3	BAU	D2	D3	BAU	BAU	BAU		
BC4	D3	D3	D3	D1	D3	D3		
BC5	D3	D3	D3	BAU	D1	D4		
BC6	D2	D3	D3	BAU	D1	D1		
BC7	BAU	D3	D3	BAU	D1	D1		
BC8	D3	D3	D3	D1	D3	D3		
BC9	D3	D3	D3	D1	D3	D3		








Figure 6-23 Greenhouse Gases (in detail, relative of each phase to total) in GWP100 for the 'high values'

6.6.2 Sensitivity to length of the circuits

	BAT -	ength sen	sitivity	LLCC -	length sen	sitivity
	low	ref	high	low	ref	high
BC1	D3	D3	D3	D3	D3	D3
BC2	D3	D3	D3	BAU	BAU	BAU
BC3	D2	D2	D2	BAU	BAU	BAU
BC4	D3	D3	D3	D3	D3	D3
BC5	D3	D3	D3	D1	D1	D1
BC6	D3	D3	D3	BAU	D1	D1
BC7	D3	D3	D3	BAU	D1	D1
BC8	D3	D3	D3	D3	D3	D3
BC9	D3	D3	D3	D3	D3	D3

Table 6-42: design option sensitivity to circuit length



6.6.3 Sensitivity to product lifetime

Table 6-43: Life time parameters per sector

	short pro	oduct life	Refe	rence	long product life		
Sector	Replace- ment rate	Product life	Replace- ment rate	Product life	Replace- ment rate	Product life	
Unit	%	year	%	year	%	year	
Residential sector	2.10%	40	1.18%	64	0.80%	84	
Services sector	7.08%	13	3.20%	25	1.70%	40	
Industry sector	7.08%	12	2.80%	25	1.37%	40	



6.6.3 Sensitivity to product lifetime

	BAT - li	fetime ser	nsitivity	LLCC - I	ifetime sei	nsitivity
	low	ref	high	low	ref	high
BC1	D3	D3	D3	D1	D3	D3
BC2	D3	D3	D3	BAU	BAU	D1
BC3	D1	D2	D3	BAU	BAU	BAU
BC4	D3	D3	D3	D3	D3	D3
BC5	D3	D3	D3	BAU	D1	D4
BC6	D3	D3	D3	BAU	D1	D1
BC7	D3	D3	D3	BAU	D1	D1
BC8	D3	D3	D3	D3	D3	D3
BC9	D3	D3	D3	D3	D3	D3

Table 6-53: Design option sensitivity to product lifetime







14/11/2014

Preparatory Studies for Product Group in the Ecodesign Working Plan 2012-2014: Lot 8-Power Cables

Stakeholder meeting: Task 7 - scenarios

Paul Van Tichelen - Dominic Ectors

Brussels, DG Enterprise

13 November 2014

Task 7 structure

- » Stakeholders position to be provided
- » Policy options
- » Scenarios
- » Socio-economic Impact
- » Sensitivity analysis



Policy options- at product level?

- » generic ecodesign requirements on information? (increase awareness
 - » E.g. maximum DC ohmic resistance per kilometer at 20°C
 - » E.g. on websites and/or packages:
 - » Cable losses per kilometer @ 50, 100 % load
 - » Tracking data of real measured ohmic resistance? (quality control data)
- » Scope:
 - » IEC 60502-1: Power cables with extruded insulation and their accessories for rated voltages from 1kV up to 30 kV. Remark: restricted to cables with a rated voltage U0/U (Um) of 0.6/1 (1.2kV)
 - » EN 50525-1 Electric cables: LV energy cables of rated voltages up to and including 450/750 (U0/u) Remark: restricted to EN50525 cables for fixed wiring



Policy option at product level and/or circuit level

- » Are electrical circuits in building products?
 - » No? > elements or components of a building and so far were not considered as 'products' in European legislation
 - » not satisfy the minimum volume of sales requirement of article 15 (5) of the ErP regulation (2009/125/EC
 - » cannot be moved or relocated and the 'free movement of goods' is therefore irrelevant
 - » Currently don't belong to the product categories of the CE product marking directive (93/68/EEC).
- » Therefore other policy proposals are included



Policy options at circuit/installation level - scope

- » Scope
 - » "installed Low Voltage power cables in buildings after the meter"
 - » Suggest to focus, e.g.:
 - » circuits between the transformer(s) and the main distribution board of the building, after the meter;
 - » Electric circuits between the main distribution board and the secondary distribution boards;
 - » Dedicated electric circuits from the main and secondary distribution boards to electrical consumers with a high load factor (large number of operating hours per year) (e.g. HVAC components and servers).



Policy options – Specific requirements to increase CSA

- » Require LCC (economic optimisation)
 - » IEC 60287-3-2 Electric cables Calculation of the current part 3-2: sections on operating conditions – Economic optimization of power cable size?
 - » Web tool or software tool?
 - Introduction of an extra correction factor based on the load factor of the electric consumer. HD 60364-5-52:2011 (IEC 60364-5-52:2009) defines two correction factors to determine the maximum allowable current-carrying capacity of an electric circuit (apart from method of installation & ambient temperature)?
 - » Inclusion in the EPB Directive (2010/31/EU)?
 - » updated prIEC 60364-8-1 (EE in electrical installations), updatedEN15603, and a new standard EN15XXX?



Policy options – Generic requirements to increase CSA

- » Before installation:
 - Information: ref., the design current (lb), rated current of the circuit (In), L, estimated load factor, Kf or equivalent hours of peak load?
 - » Note: updated prIEC 60364-8-1? Align with IEC 60287-3-2 on economic optimization method?
- » After installation:
 - » Measure & indicate resistance
 - » Add label with parameters
 - » Note: updated prIEC 60364-8-1?
- » In BACS (Building Automation and Control Systems)
 - » the load factor (LF) and load form factor (Kf) and/or equivalent or equivalent time of peak load
 - » include monitoring functions in standard EN 15232 (2007)?



7.2.1 Scenario definition

Scenario	BC1	BC2	BC3	BC4	BC5	BC6	BC7	BC8
BAU	BAU	BAU	BAU	BAU	BAU	BAU	BAU	BAU
BAT	D3	D3	D2	D3	D3	D3	D3	D3
LLCC	D3	BAU	BAU	D3	D1	D1	D1	D3
IV	D1	BAU	BAU	D1	D1	BAU	BAU	D1

- » Circuits are not products !!!
- Scenarios **not** based upon ecodesign measures !!!!!
- » Gives an indication if **all** circuits in services and industry are considered
- » 'Improved' circuits replace BAU circuits at replacement rate (product life)
- » Correction factors in T5 are used! Meaning low load, long circuits.



7.2.2.1 Main input parameters for the analysis

Discount rate	4.0%
Inflation rate	2.0%
Energy Escalation rate	4.0%
Electricity rate (€/kWh)	0.11
Stock growth rate services sector	1.9%
Stock growth rate industry sector	2.9%
Sales growth rate services sector	3.2%
Sales growth rate industry sector	2.8%
Product lifetime services sector (years)	25
Product lifetime industry sector (years)	25

Table 7-5: Main input parameters



7.2.2.2 Stock




Figure 7-1: Total stock of circuits (in circuit units)


Figure 7-2: Total stock of circuits (in Kton conductor material)



Eurostat EU electricity consumption

Table 2-12 EU28 annual final consumption of electricity by industry and households/services in TWh¹⁶

			Final annual energy consumption in TWh											
	Year	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	201	
Industry		1075	1081	1089	1120	1133	1131	1142	1119	966	1030	1037	100	
Households		744	753	787	798	806	818	810	820	820	845	803	82	
Services		703	716	741	763	780	822	837	864	867	904	885	89	



+2,0 up to +2,5% annual growth rate in services

In this model is:

electricity consumption growth = stock growth

=> Stock growth for industry: 0% ??



7.2.2.3 Annual sales of circuits





Figure 7-8: Annual sales of circuits (in Kton conductor material)



7.2.2.4 Annual demand of electricity due to losses in circuits



	1990	1995	2000	2005	2010	2015	2020	2025	2030	2085	2040	2045	2050
BAU	26.02	29.24	32.88	36.99	41.65	45.91	52.88	59.64	67.30	75.99	85.85	97.05	109.77
BAT	26.02	29.24	32.88	36.99	41.65	45.91	46.30	43.89	41.20	38.20	34.85	36.55	41.38
LLCC	26.02	29.24	32.88	36.99	41.65	45.91	47.08	45.77	44.33	42.77	41.05	44.01	49.92
IV	26.02	29.24	32.88	36.99	41.65	45.91	49.95	52.62	55.68	59.17	63.17	70.17	79.42
Absolute (dlffe ren ce	to BAU											
BAT	0.00	0.00	0.00	0.00	0.00	0.00	-6.58	-15.75	- 26.10	-37.79	-50.99	-60.50	-68.39
LLCC	0.00	0.00	0.00	0.00	0.00	0.00	-5.80	-13.87	-22.97	-33.22	-44.79	-53.04	-59.86
IV	0.00	0.00	0.00	0.00	0.00	0.00	-2.93	-7.02	-11.62	-16.82	-22.68	-26.88	-30.36
Relative d	lfference	to BAU											
BAT	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-12.4%	-26.4%	-38.8%	-49.7%	-59.4%	-62.3%	-62.3%
LLCC	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-11.0%	-23.3%	-34.1%	-43.7%	-52.2%	-54.6%	-54.5%
IV	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-5.5%	-11.8%	-17.3%	- 22.1%	-26.4%	-27.7%	-27.7%

Table 7-16: Annual circuit electricity losses (in TWh/yr)



7.2.2.5 Annual emissions of CO_2 eq.




Figure 7-15: Annual total GWP (in Mt CO2 eq.)


Figure 7-16: Cumulative GWP (in Mt CO2 eq.)

	1990	1995	2000	2005	2010	2015	2020	2025	2030	2085	2040	2045	2050
BAU	14.71	90.66	170.57	256.99	352.30	456.74	570.69	694.07	826.89	974.06	1140.33	1328.32	1540.96
BAT	14.71	90.66	170.57	256.99	352.30	456.74	588.64	717.36	843.14	969.17	1097.53	1224.59	1368.11
LLCC	14.71	90.66	170.57	256.99	352.30	456.74	578.51	697.48	813.72	930.48	1049.99	1171.98	1309.81
IV	14.71	90.66	170.57	256.99	352.30	456.74	572.31	690.86	812.42	940.99	1080.03	1231.31	1402.38
Absolute (diffe ren ce	to BAU											
BAT	0.00	0.00	0.00	0.00	0.00	0.00	17.96	23.29	16.25	-4.89	-42.80	-103.73	-172.85
LLCC	0.00	0.00	0.00	0.00	0.00	0.00	7.82	3.41	-13.17	-43.57	-90.34	-156.34	-231.15
IV	0.00	0.00	0.00	0.00	0.00	0.00	1.62	-3.20	-14.47	-33.06	-60.30	-97.01	-138.59
Relative d	Ifference t	to BAU											
BAT	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+3.1%	+3.4%	+2.0%	-0.5%	-3.8%	-7.8%	-11.2%
LLCC	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+1.4%	+0.5%	-1.6%	-4.5%	-7.9%	-11.8%	-15.0%
IV	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.3%	-0.5%	-1.8%	-3.4%	-5.3%	-7.3%	-9.0%



Table 7-21: Cumulative GWP (in Mt CO2 eq.)

7.3 Socio-economic impact analysis 7.3.1 Annual expenditure



7.3.2 Impact on workforce

- » can lead to significant job creation within EU28 in the sector of local electrical contracting, local engineering.
- » Stakeholders: please provide input and figures if possible



7.3.3 Any other relevant impact ?

» Impact on the market structure, size of the companies, role and responsibility ...



7.4 Sensitivity analysis7.4.1 sensitivity case 1

Discount rate	4.0%
Inflation rate	2.0%
Energy Escalation rate	4.0%
Electricity rate (€/kWh)	0.11
Stock growth rate services sector	1.0%
Stock growth rate industry sector	1.0%
Sales growth rate services sector	1.7%
Sales growth rate industry sector	1.4%
Product lifetime services sector (years)	40
Product lifetime industry sector (years)	40

Table 7-25: Sensitivity case 1 - Main input parameters



7.4.1.1 Stock





Figure 7-21: Sensitivity case 1 - Total stock of circuits (in Kton conductor material)



7.4.1.3 Annual demand of electricity due to losses in circuits




	1990	1995	2000	2005	2010	2015	2020	2025	2030	2085	2040	2045	2050
BAU	34.13	35.87	37.70	39.63	41.65	43.77	46.01	48.35	50.82	53.41	56.14	59.00	62.01
BAT	34.13	35.87	37.70	39.63	41.65	43.77	43.18	41.84	40.42	38.94	37.38	35.74	34.02
LLCC	34.13	35.87	37.70	39.63	41.65	43.77	43.49	42.55	41.56	40.52	39.43	38.28	37.07
IV	34.13	35.87	37.70	39.63	41.65	43.77	44.74	45.43	46.16	45.92	47.72	48.57	49.45
Absolute	dlffe ren ce	to BAU											
BAT	0.00	0.00	0.00	0.00	0.00	0.00	-2.82	-6.51	- 10.39	-14.47	-18.76	-23.26	-27.99
LLCC	0.00	0.00	0.00	0.00	0.00	0.00	-2.52	-5.80	-9.26	-12.89	-16.71	-20.72	-24.94
IV	0.00	0.00	0.00	0.00	0.00	0.00	-1.27	-2.92	-4.66	-6.49	-8.41	-10.43	-12.56
Relative d	llfference t	to BAU											
BAT	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-6.1%	-13.5%	-20.5%	-27.1%	-33.4%	-39.4%	-45.1%
LLCC	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	- 5.5%	-12.0%	-18.2%	-24.1%	-29.8%	-35.1%	-40.2%
IV	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-2.8%	-6.0%	-9.2%	-12.2%	-15.0%	-17.7%	-20.2%

Table 7-36: Sensitivity case 1 - Annual circuit electricity losses (in TWh/yr)



GWP



	1990	1995	2000	2005	2010	2015	2020	2025	2030	2085	2040	2045	2050	22
BAU	18.09	107.57	195.15	283.32	373.96	466.42	560.22	654.53	748.67	845.54	947.34	1054.35	1166.81	1
BAT	18.09	107.57	195.15	283.32	373.96	466.42	567.72	663.53	753.61	840.51	925.82	1009.45	1091.31	
LLCC	18.09	107.57	195.15	283.32	373.96	466.42	563.63	655.83	742.73	826.92	910.08	992.01	1072.80	1
IV	18.09	107.57	195.15	283.32	373.96	466.42	560.84	652.95	742.24	831.45	922.52	1015.53	1110.57	
Absolute	diffe ren ce	to BAU												
BAT	0.00	0.00	0.00	0.00	0.00	0.00	7.50	9.01	4.94	-5.02	-21.53	-44.90	-75.50	
LLCC	0.00	0.00	0.00	0.00	0.00	0.00	3.41	1.31	-5.98	-18.61	-37.31	-62.34	-94.01	
IV	0.00	0.00	0.00	0.00	0.00	0.00	0.63	-1.58	-6.43	-14.08	-24.82	-38.82	-56.24	
Relative d	Ifference	to BAU												
BAT	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+1.3%	+1.4%	+0.7%	-0.6%	-2.3%	-4.3%	-6.5%	
LLCC	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.6%	+0.2%	-0.8%	-2.2%	-3.9%	-5.9%	-8.1%	
IV	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.1%	-0.2%	-0.9%	-1.7%	-2.6%	-3.7%	-4.8%	1
	BAT ILCC IV Absolute o BAT ILCC IV Relative d BAT	BAU 18.09 BAT 18.09 LLCC 18.09 IV 18.09 Absolute difference BAT 0.00 LLCC 0.00 LLCC 0.00 Re lative difference BAT +0.0% LLCC +0.0%	BAU 18.09 107.57 BAT 18.09 107.57 LLCC 18.09 107.57 IV 18.09 107.57 Absolute difference to BAU BAT 0.00 0.00 LLCC 0.00 0.00 0.00 0.00 BAT 0.00 0.00 0.00 0.00 IV 0.00 0.00 0.00 0.00 ILCC 0.00 40.09 40.09 40.09 BAT 40.09 +0.09 40.09 40.09	BAU 18.09 107.57 195.15 BAT 18.09 107.57 195.15 LLCC 18.09 107.57 195.15 IV 18.09 107.57 195.15 Absolute difference to BAU BAT 0.00 0.00 0.00 LLCC 0.00 0.00 0.00 0.00 0.00 BAT 0.00 0.00 0.00 0.00 0.00 LLCC 0.00 0.00 0.00 40.0% BAT +0.0% +0.0% +0.0% +0.0%	BAU 18.09 107.57 195.15 283.32 BAT 18.09 107.57 195.15 283.32 LLCC 18.09 107.57 195.15 283.32 IV 18.09 107.57 195.15 283.32 Absolute difference to BAU BAT 0.00 0.00 0.00 LLCC 0.00 0.00 0.00 0.00 LLCC 0.00 0.00 0.00 0.00 BAT 0.00 0.00 0.00 0.00 LLCC 0.00 0.00 0.00 0.00 RAT 0.00 0.00 0.00 0.00 IV 0.00 0.00 0.00 0.00 Relative difference to BAU BAT +0.0% +0.0% +0.0% BAT +0.0% +0.0% +0.0% +0.0%	BAU 18.09 107.57 195.15 283.32 373.96 BAT 18.09 107.57 195.15 283.32 373.96 LLCC 18.09 107.57 195.15 283.32 373.96 IV 18.09 107.57 195.15 283.32 373.96 IV 18.09 107.57 195.15 283.32 373.96 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 LCC 0.00 0.00 0.00 0.00 0.00 0.00 0.00 BAT 0.00 0.00 0.00 0.00 0.00 0.00 0.00 IV 0.00 0.00 0.00 0.00 0.00 0.00 0.00 ILCC 0.00 0.00 0.00 0.00 0.00 0.00 BAT +0.0% +0.0% +0.0% +0.0% +0.0% +0.0% LCC +0.0% +0.0% +0.0% +0.0%	BAU 18.09 107.57 195.15 283.32 373.96 466.42 BAT 18.09 107.57 195.15 283.32 373.96 466.42 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 IV 18.09 107.57 195.15 283.32 373.96 466.42 IV 18.09 107.57 195.15 283.32 373.96 466.42 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 BAT 0.00 0.00 0.00 0.00 0.00 0.00 ILCC 0.00 0.00 0.00 0.00 0.00 0.00 ILCC 0.00 0.00 0.00 0.00 0.00 0.00 IV 0.00 0.00 0.00 0.00 0.00 0.00 ILCC 0.00% +0.0% +0.0% +0.0% +0.0% +0.0% BAT +0.0% +0.	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 Absolute difference to BAU 283.32 373.96 466.42 560.84 BAT 0.00 0.00 0.00 0.00 0.00 0.00 7.50 LCC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 IV 0.00 0.00 0.00 0.00 0.00 0.00 0.63 Relative difference to BAU BAT 40.0% 40.0% 40.0% 40.0% 40.0% 40.0%	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 LCC 0.00 0.00 0.00 0.00 0.00 3.41 1.31 IV 0.00 0.00 0.00 0.00 0.00 3.41 1.31 IV 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 IV 0.00 <td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 664.53 748.67 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 IV 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 Absolute difference to BAU U U 0.00 0.00 0.00 0.00 7.50 9.01 4.94 LCC 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 IV 0.00 0.00 0.00 0.00 0.00 0.00 0.63 -1.58 -6.43 Relative difference to BAU</td> <td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 831.45 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 LICC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 IV 0.00 0.00 0.00</td> <td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 IV 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 831.45 922.52 Absolute difference to BAU U U 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 LCC 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61<td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 LCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.74 831.45 922.52 1015.53 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 LCC 0.00 0.00</td><td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 1166.81 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 566.84 652.95 742.24 831.46 922.52 1015.53 1110.57 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 -75.50 LCC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 -37.31</td></td>	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 664.53 748.67 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 IV 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 Absolute difference to BAU U U 0.00 0.00 0.00 0.00 7.50 9.01 4.94 LCC 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 IV 0.00 0.00 0.00 0.00 0.00 0.00 0.63 -1.58 -6.43 Relative difference to BAU	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 831.45 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 LICC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 IV 0.00 0.00 0.00	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 IV 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.24 831.45 922.52 Absolute difference to BAU U U 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 LCC 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 <td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 LCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.74 831.45 922.52 1015.53 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 LCC 0.00 0.00</td> <td>BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 1166.81 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 566.84 652.95 742.24 831.46 922.52 1015.53 1110.57 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 -75.50 LCC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 -37.31</td>	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 LCC 18.09 107.57 195.15 283.32 373.96 466.42 563.63 655.83 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.73 826.92 910.08 992.01 IV 18.09 107.57 195.15 283.32 373.96 466.42 560.84 652.95 742.74 831.45 922.52 1015.53 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 LCC 0.00 0.00	BAU 18.09 107.57 195.15 283.32 373.96 466.42 560.22 654.53 748.67 845.54 947.34 1054.35 1166.81 BAT 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 567.72 663.53 753.61 840.51 925.82 1009.45 1091.31 LLCC 18.09 107.57 195.15 283.32 373.96 466.42 566.84 652.95 742.24 831.46 922.52 1015.53 1110.57 Absolute difference to BAU BAT 0.00 0.00 0.00 0.00 0.00 7.50 9.01 4.94 -5.02 -21.53 -44.90 -75.50 LCC 0.00 0.00 0.00 0.00 0.00 0.00 3.41 1.31 -5.93 -18.61 -37.31



Table 7-41: Sensitivity case 1 - Cumulative GWP (in Mt CO2 eq.)

7.4.2 sensitivity case 2

Discount rate	2.5%
Inflation rate	1.0%
Energy Escalation rate	4.0%
Electricity rate (€/kWh)	0.11
Stock growth rate services sector	1.9%
Stock growth rate industry sector	2.9%
Sales growth rate services sector	3.2%
Sales growth rate industry sector	2.8%
Product lifetime services sector (years)	25
Product lifetime industry sector (years)	25

Table 7-45: Sensitivity case 2 - Main input parameters



7.4.2.1 Annual expenditure due to electricity losses




Figure 7-41: Sensitivity case 2 - Annual expenditure due to electricity losses (in mln. euro)



7.4.3 sensitivity case 3

Discount rate	4.0%
Inflation rate	2.0%
Energy Escalation rate	1.0%
Electricity rate (€/kWh)	0.11
Stock growth rate services sector	1.9%
Stock growth rate industry sector	2.9%
Sales growth rate services sector	3.2%
Sales growth rate industry sector	2.8%
Product lifetime services sector (years)	25
Product lifetime industry sector (years)	25

Table 7-49: Sensitivity case 3 - Main input parameters



7.4.3 Annual expenditure due to electricity losses




Figure 7-42: Sensitivity case 3 - Annual expenditure due to electricity losses (in mln.

	1990	1995	2000	2005	2010	2015	2020	2025	2030	2085	2040	2045	2050
BAU	3458.97	3707.40	3976.03	4266.66	4581.27	4922.00	5291.23	5691.54	6125.75	6596.98	7108.62	7664.40	8268.39
BAT	3458.97	3707.40	3976.03	4266.66	4581.27	4922.00	4632.92	4188.65	3750.34	3316.64	2885.19	2886.53	3117.06
LLCC	3458.97	3707.40	3976.03	4266.66	4581.27	4922.00	4710.84	4367.70	4035.23	3712.78	3399.70	3475.88	3759.89
IV	3458.97	3707.40	3976.03	4266.66	4581.27	4922.00	4997.75	5021.88	5067.88	5136.91	5230.31	5541.47	5981.73
Absolute difference to BAU													
BAT	0.00	0.00	0.00	0.00	0.00	0.00	-658.32	-1502.89	-2375.42	-3280.35	-4222.43	-4777.86	-5151.33
LLCC	0.00	0.00	0.00	0.00	0.00	0.00	-580.40	-1323.84	-2090.52	-2884.20	- 3708.92	-4188.51	-4508.50
IV	0.00	0.00	0.00	0.00	0.00	0.00	-293.49	-669.66	-1057.87	-1460.07	-1878.31	-2122.93	-2286.66
Relative difference to BAU													
BAT	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-12.4%	-26.4%	-38.8%	-49.7%	-59.4%	-62.3%	-62.3%
LLCC	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-11.0%	-23.3%	-34.1%	-43.7%	-52.2%	-54.6%	-54.5%
IV	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	+0.0%	-5.5%	-11.8%	-17.3%	- 22.1%	-26.4%	-27.7%	-27.7%



Table 7-50: Sensitivity case 3 - Annual expenditure due to electricity losses (in mln.

© 2013, VITO NV

euro)